33 Oriel Road - Cert_.pdf

158

LANDLORD/HOMEOWNER GAS SAFETY RECORD

Gas safe is a registered trade mark of HSE and is used under licence.

ered Business
lo 671362
r's Name Cole Masters
licence Number 671362
res of Plumbing
Canville Boulevard
bington
23SCT
07345190

(Ms)
Oriel Road
or Ferry

ner/Landlord (or agent where appropriate)
/Ms) Hamilton Estates
eland Street
enhead

ces tested 2

Appliance Details

	Location of	Type	Manufacturer	Model	Owned by Landlord/Homeowner Yes/No	Inspected Yes/No	Type of flue
1	Kitchen	Boiler	Vaiera Gasi Heat Plus		Yes	Yes	DS
2		Hob	Lamona Ct Eng Gas hob		Yes	Yes	—
3							
4							

Inspection Details

	Operating pressure in mbar and/or heat input kW/h or Btu/h	Operation of safety device(s) Pass/Fail/NA	Ventilation satisfactory Yes/No	Visual condition of flue and termination Pass/Fail/NA	Flue operation checks Pass/Fail/NA	Combustion analyser reading (if applicable)	Appliance serviced Yes/No	CO Alarm fitted Yes/No	CO Alarm tested (if fitted) Pass/Fail/NA	SAFE TO USE Yes/No
	4kw	Pass	Yes	Pass	Pass	0.0000	No	No	NA	Yes
	Hob	Pass	Yes	Pass	—	—	No	No	NA	Yes

Select an area to comment on

Related Defect(s) Identified	GIUSP classification eg. AR, ID	Warning/Advisory Record insert form serial No*

Action Taken (Following should be completed to defect above)

of Work carried out

* Refer to separate Warning/Advisory Record

select as appropriate and relevant

tallation pipework visual inspection? Pass / Fail / NA
pply pipework visual inspection? Pass / Fail / NA
ontrol Valve access satisfactory? Pass / Fail
ntness test? Pass / Fail / NA
uipotential bonding satisfactory? Pass / Fail

Record issued by: Signature
Print Name Cole Masters
Received by: Signature
Date appliance(s)/flue(s) checked 20/5/20

ATTENTION
Next safety check due by: 20/5/21

for other licensed gas safe inspection issued records & labels in this range

Save as...