



Domestic/Landlord Gas Safety Record

Safety inspection and reporting carried out in accordance with Gas Safety (Installation and Use) Regulations and the Gas Industry Unsafe Situations Procedure. Unless stated otherwise, no detailed internal inspection of flues (Integrity, Construction and Lining) has been carried out.

Certificate Reference
Sps150w00d

Certificate No: 240421

Engineers Details

Trading Title
Wirral Gas Services

Address
Sherlock House
Manor Road
Wallasey

Post Code: CH45 4UB

Installation Details

Installation Address
Thomas Ellis
50 Woodchurch Lane
Prenton
Wirral

Post Code: CH42 9PL

Client Details

Client Address
Steve Best
28 Thurston Road
Irby
Wirral

Post Code: CH61 0HF

Gas Safe No: 199605

Telephone No: 07831554321

Telephone No:

Telephone No: 07970505034

Appliance Details

Inspection Details

Location	Appliance Type	Make	Model	CO2 Reading (%)	CO Reading (ppm)	FlueType (OF/RS/FL)	Appliance Inspected (YES/NO/NA)	Combustion Analysis Reading (CO/CO2)	Landlords Appliance (YES/NO/NA)	Operating Pressure(mbar) or Heat Input(KW)	Safety Device(s) Correct Operation (YES/NO/NA)	Ventilation Provision Satisfactory (YES/NO)	Visual Condition Of Flue and Termination Satisfactory (YES/NO/NA)	Flue Performance Test (PASS/FAIL/NA)	Appliance Serviced (YES/NO/NA)	Appliance Safe To Use (YES/NO)			
1 Understairs	Combi Boiler	Worcester	24 JUNIOR RSF	NA	NA	RS	YES	NA	YES	24 kW	YES	YES	YES	NA	NO	NA			
2 Kitchen	Hob	Essentials	Clr	NA	NA	FL	YES	NA	YES	8.5 kW	YES	YES	NA	NA	NA	YES			
3																			
4																			
5																			
Faults/Notes													Remedial Work Taken					Warning Notice Fixed	
1																			
2																			
3																			
4																			
5																			

Emergency Control Valve Accessible: Yes

Gas Tightness Satisfactory: YES

Signatures

Report Issued By:

Name: Lee McGuire

Gas ID Number: 5078571

Number of Appliances Tested:

Equipotential Bonding: Yes

Report Received By:

Signed: *Steve Best*

Date: Sat-24-Apr-2021

NEXT INSPECTION DUE ON

Sun-24-Apr-2022

Installation Pass: Yes

Name: Steve Best

Signed: *Steve Best*

Date: Sat-24-Apr-2021